

From CO House Bill 09-1091

House Bill 09-1091: "...OPERATIONAL CARBON MONOXIDE ALARM IS INSTALLED WITHIN FIFTEEN FEET OF THE ENTRANCE TO EACH ROOM LAWFULLY USED FOR SLEEPING PURPOSES OR IN A LOCATION AS SPECIFIED IN ANY BUILDING CODE ADOPTED BY THE STATE OR ANY LOCAL GOVERNMENT ENTITY".

"...OPERATIONAL CARBON MONOXIDE ALARM INSTALLED WITHIN TWENTY-FIVE FEET OF ANY FUEL-FIRED HEATER OR APPLIANCE, FIREPLACE, OR GARAGE OR IN A LOCATION AS SPECIFIED IN ANY BUILDING CODE ADOPTED BY THE STATE OR ANY LOCAL GOVERNMENT ENTITY".